

REGIONAL TRANSIT AUTHORITY

PUBLIC NOTICE

IFB 2026-031 Installation of Transfer Switches & Emergency Generators

Addendum I

Acknowledge receipt of this addendum in the bid submission. This addendum is a part of the Contract Documents and shall be included in the Contract Documents. Changes made by the addenda take precedence over information published at an earlier date.

Invitation for Bid No. 2026-031 has been amended as follows:

Questions:

Can you please confirm when the prebid conference is? It is not stated in the bid documents. Also the bid documents state there is a pre-bid conference form. I do not see that is provided. If this is needed can you please provide? **There is no pre-bid for this solicitation.**

Are bids due both online and in person? Or are bids just due either online or just in person? Please confirm how the bid is supposed to be submitted. **You can submit bids online or in person. Doing both are not required.**

Can you please provide any insurance and bonding requirements? Please see section 2.13 for insurance. **A 5% bid bond is required.**

The following items are referenced in the bid documents, but do not see that they are provided. Can you please provide the following: Technical Specs/Specs and Attachment I. **Scope of work is provided in procureware under documents.**

Scope of work #4 Main Facility is this the Maintenance Facility next to lower Algiers ferry terminal? **YES**

For #4 Main Facility, if this is the Maintenance Facility Building, this building does not have a main breaker in the existing electrical panel to install a safety slide bar. Also, existing panel breakers are obsolete. Please advise on new scope of work. **According to our ferry operator, LabMar, the maintenance building does have a main breaker. Please advise when you would like to visit and a representative will show you around the property.**

For Algiers Point Ferry Terminal, This facility is under renovations. Will we have access to this site to confirm power sources can be de energized for the new install? **YES, just let us know when you would like to go by the property to confirm.**

**Ronald Baptiste
Interim Chief Executive Officer
Regional Transit Authority**

For all locations if transfer switch is installed on Jacking Platform will we be able to close a lane of traffic for testing purposes during normal business hours, so owner supplied generator can park in lane and owner cord from portable generator can reach receptacle on platform? **The transfer switch does not need to be located on the jacking platform.**

Manual Transfer switches at Lower Algiers, and Chalmette location can be installed next to the current Entergy meter location. Please reply with a new scope of work if this is possible? **The transfer switches should be placed near the current meter locations, it is not necessary to place them on the jack towers.**

**Ronald Baptiste
Interim Chief Executive Officer
Regional Transit Authority**